

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 123

Dated:

It is certified that an inspection team headed by

(Name of Officers with designation) from

inspected the

(Name & Address of the school) on

Water Test Report (Attached) bearing no.

of

TS DAY PUBLIC SCHOOL

(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal:

Name


Designation

Name & Address of the Office / Department

To

TS DAY PUBLIC SCHOOL  
BAHARAGORA, E. SINGUBHUM, Jh.  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water Testing Laboratory**  
Office of the Executive Engineer (DW&SD)  
Near Adityapur Thana, Jamshedpur-831013  
Email: dlwtl.jamshedpur@gmail.com

Report No:	JSR/2025/85	Memo no:	319/02-09-2025
Issue To/ Name and Address of customer:	Tarapada Sarangi DAV Public School Baharagora	Sample code:	250901GWBG01
Sample Type:	Drinking water (Boring Water)	Sample collected by	
Sample Received on:	01/09/2025	Sample Description:	<1000ml, Good condition at 4°C
Test start on:	01/09/2025	Date completion on:	02/09/2025
ULR:			

**Test Result**

Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS - 10500-2012 (Second Revision)	
					Acceptable Limit	Permissible Limit (Absence of Alternate source)
1	pH, at 25°C	-	6.58	APHA 24th Ed.2023-4500-H <sup>+</sup> B, (Electrometric method)	6.5 - 8.5	No relaxation
2	Turbidity	NTU max	01	APHA 24 <sup>th</sup> Ed.2023-2130 B, (Nephelometric method)	1	5
3	Alkalinity as CaCO <sub>3</sub>	mg/L max	56	APHA 24 <sup>th</sup> Ed.2023-2320 B, (Titration method)	200	600
4	Calcium as (Ca)	mg/L max	17.6	APHA 23 <sup>rd</sup> Ed.2017-3500 Ca B, (EDTA Titration method)	75	200
5	Magnesium as Mg	mg/L max	5.76	APHA 24 <sup>th</sup> Ed.2023-3500-Mg B, (Calculation method)	30	100
6	Hardness as CaCO <sub>3</sub>	mg/L max	68	APHA 24 <sup>th</sup> Ed.2023-2340 C, (EDTA Titration method)	200	600
7	Total Dissolved Solids at 180°C	mg/L max	82	APHA 24 <sup>th</sup> Ed.2023-2540 C, Total Dissolved Solids Dried at 180°C	500	2000
8	Chloride (cl)	mg/L max	17.86	APHA 24 <sup>th</sup> Ed.2023-4500 Cl B, (Argentometric method)	250	1000
9	Colour 25°C	Hazen	01	IS:3025, (Part-4)	5	15
10	Taste	-	Agreeable	IS:3025, (Part-5)	Agreeable	-
11	Odour	-	Agreeable	IS: 3025, (Part-7)	Agreeable	-

**Specific contractual notes: -**

- ◆ The results listed refer only to the tested sample as received from the customer.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ This report can not be reproduced, except when in full, without the written permission of the Lab In-charge.
- ◆ Tested Sample shall be retained up to Seven Days from the date of issue of the certificate.
- ◆ The laboratory is responsible for all the information given in this test report.
- ◆ All disputes are subjected to the Jamshedpur Jurisdiction.
- ◆ NOTE:- BDL=Below Detection Limit / DL=Detection Limit.

*Supriya Kumari*  
02/09/2025

Supriya Kumari  
Authorised Signatory  
(Quality Manager)

**Quality Manager**  
District Level Water Testing Laboratory  
D.W. & S. Division, Jamshedpur





**District Level Water Testing Laboratory**  
**Office of the Executive Engineer (DW&SD)**  
**Near Adityapur Thana, Jamshedpur-831013**  
**Email: dlwtl.jamshedpur@gmail.com**

Report No.	JSR/2025/85	Sample code	250901GWBG01
Name and Address of Customer	Tarapada Sarangi DAV Public School Baharagora		Memo no:
			319/02-09-2025
Sample Type	Drinking water (Boring Water)	Sample Collected by:	Subham jana
Sample receipt on	01/09/2025	Sample description:	<1000ml, Good Condition at 4°C
Date of start Analysis	01/09/2025	Date of completion	02/09/2025
ULR:			

### Bacteriological Test Report

S.No	Parameter	Test Method	Unit	Result	Remarks
01	Total Coliform	APHA 9222B 24th Edition 2023	Cfu/100ml.	Absent	Shall not be detectable in any 100 ml sample
02	Fecal Coliform	APHA 9222D 24th Edition 2023	Cfu/100mL	Absent	Shall not be detectable in any 100 ml sample

**Specific contractual notes: -**

- ◆ The results listed refer only to the tested sample as received from the customer.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ This report can not be reproduced, except when in full, without the written permission of the Lab In-charge
- ◆ Tested Sample shall be retained up to Seven Days from the date of issue of the certificate.
- ◆ The laboratory is responsible for all information given in this test report.
- ◆ All disputes are subjected to the Jamshedpur Jurisdiction.

*Supriya Kumari*  
02/09/2025

Supriya Kumari  
Authorised Signatory  
(Quality Manager)

**Quality Manager**  
**District Level Water Testing Laboratory**  
**D.W. & S. Division, Jamshedpur**

- ◆ The results listed refer only to
- ◆ This report, in full or in part, shall
- ◆ This report can not be reproduced
- ◆ Tested Sample shall be retained
- ◆ The laboratory is responsible for
- ◆ All disputes are subjected to

End of the Report.....

Tested by: Manisha